

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.
dwtl1t1@gmail.com

TEST REPORT

Name & Address of Customer : MSM Convent Senior Secondary School Chohla Sahib , Tarn Taran		Customer Reference No.	No : Nil Dated : 02/06/2023
		Sample Submitted by	Upkar Singh
		Date of Sample Receipt	02/06/2023
		Analysis Starting Date	02/06/2023
		Analysis completion Date	03/06/2023
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC103872300000146F	Sample Type :	Treated Water
Test Report No.:	DWTLTT/2324/00070	Date of Issue :	03/06/2023
Registration no.:	DWTLTT/REG2324/00095	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Dhun Road / NA
Village :	Chohla Sahib	Habitation :	Chohla Sahib
Block:	Chohla Sahib	District :	Tarn Taran
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.70	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 - 1984) (RA 2017)
5	TDS	90	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	0.01	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	64	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	60	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	8.02	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	9.72	30	100	mg/l	APHA (23rd Ed,2017) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	9.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Chairman
M.S.M Convent School
Dhun Road, Chohla Sahib, (T.T.)

The Principal
M.S.M. Convent Sr. Sec. School
Dhun Road, Chohla Sahib (T.T.)
Aff. No. 1630836, School Code-20305

Mr. Pankaj Kumar
Mr. Pankaj Kumar
Technical Manager
Authorized Signatory
For, District Water Testing Laboratory, Tarn Taran

End of the Test Report

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.
dwtl1@gmail.com

To,

MSM Convent Senior Secondary School
Chohla Sahib , Tarn Taran

No.: DWTLTT/2324/00070 Dated : 03/06/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. Nil Dated: 02/06/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 02/06/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Tarn Taran

D/A : Test Report


The Principal

M.S.M. Convent Sr. Sec. School
Dhun Road, Chohla Sahib (T.T.)
Aff. No. 1630836, School Code-20900



Authorized Signatory
For, District Water Testing Laboratory, Tarn
Taran


Chairman
M.S.M Convent School
Dhun Road, Chohla Sahib, (T.T.)